



2012001868M



2012建材质监认字15号



检测
CNAS L1449

检 验 报 告

TEST REPORT

No.: GGS1308004

Sample Name Opening aluminium window

Client YINTEC GUANGYA CURTAIN WALL&WINDOW
DOOR SYSTEM ENGINEERING CO., LTD

Manufacturer GUANGYA CURTAIN WALL&WINDOW
DOOR SYSTEM ENGINEERING CO., LTD

Test Category Sample test



国家建筑材料工业建筑五金水暖产品质量监督检验测试中心
NATIONAL BUILDING MATERIAL INDUSTRY HARDWARE AND PLUMBING
EQUIPMENT QUALITY SUPERVISION AND TEST CENTER



No. GGS1308004

TEST REPORT OF NATIONAL BUILDING MATERIAL INDUSTRY HARDWARE
AND PLUMBING EQUIPMENT QUALITY SUPERVISION AND TEST CENTER

P 1 of 2

Sample Name	Opening aluminium window	Type / Model	AHM85 series Opening window 1500mm*1500mm
Quantity	1 set	Brand	—
Client	YINTEC GUANGYA CURTAIN WALL&WINDOW DOOR SYSTEM ENGINEERING CO.,LTD	Test Category	Sample test
Manufacturer	GUANGYA CURTAIN WALL&WINDOW DOOR SYSTEM ENGINEERING CO.,LTD	Accept Date	2013.08.26
Name of Engineering	—	Sample State	Undamaged
Serial Number or Production Date	2013.07.25	Test Date	2013.08.27
Test Place	No.4 Dahongmen West Road Fengtai District Beijing		
Reference Documents	GB/T 8485-2008 The graduation and test method for airborne sound insulating properties of windows and doors		
Test Item	Weighted airborne sound reduction index		
(Conclusion)	<p>The sample according to GB/T 8485-2008 standard, weighted airborne sound reduction index and spectrum adaptation term is: $R_w(C;C_T) = 34(-1;-2)$dB.</p>		
Remark	<p>1. Sample actual size: width: 1500mm, height: 1500mm. 2. Manufacturer name provide by client.</p>		
<p>Approved by: <i>Couyongding</i> Verified by: <i>Chen yi dun</i> Compiled by: <i>Zheng yn</i></p>			

